



24 HOUR TURN-A-ROUND



contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

Windstorm Mitigation Inspection

Inclusions:

- A. Uniform Mitigation Verification Inspection Form OIR-B1-1802**
- B. One complete set of supporting supporting digital color photos**
- C. Deficiency Report (if applicable)**



121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy. This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

NAME 121 GOLDEN CONDO ASSC			DATE 4/7/2021		
ADDRESS 121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009			COUNTY BROWARD		
PHONE 239-330-0289		YEAR BUILT 1970	STORIES 14		AGENT Amanda
EMAIL TID20042@HOTMAIL.COM		CARRIER / POLICY #		UNIT / BUILDING# FOR REFERENCE ONLY	

NOTE: Any documentation used in validating the compliance or existence of each construction or mitigation attribute must accompany this form. At least one photograph must accompany this form to validate each attribute marked in questions 3 through 7. The insurer may ask additional questions regarding the mitigated feature(s) verified on this form.

- 1. Building Code:** Was the structure built in compliance with the Florida Building Code (FBC 2001 or later) OR for homes located in the HVHZ (Miami-Dade or Broward counties), South Florida Building Code (SFBC-94)?
- A. Built Complying With FBC** Year Built _____ Homes built in 2002/2003 provide a permit application with a date after 3/1/2002: Building Permit Application Date (MM/DD/YYYY)
 - B. For the HVHZ Only: Built in compliance with the SFBC-94: Year Built** Application Date (MM/DD/YYYY) For homes built in 1994, 1995, & 1996 provide a permit application with a date after 9/1/1994: Building Permit
 - C. Unknown or does not meet the requirements of Answer "A" or "B"**

2. Roof Covering: Select all roof covering types in use. Provide the permit application date OR FBC/MDC Product Approval number OR Year of Original Installation/Replacement OR indicate that no information was available to verify compliance for each roof covering identified

2.1 Roof Covering Type: Permit Application Date FBC or MDC Product Approval # Year of Original Installation No Information Provided for Compliance or Replacement

- 1. Asphalt/Fiberglass Shingle
- 2. Concrete/Clay Tile
- 3. Metal
- 4. Built-up 5/20/15 2015-1893-NRPR-0 2015
- 5. Membrane
- 6. Other

- A. All roof coverings listed above meet the FBC with a FBC or Miami-Dade Product Approval listing current at time of installation OR have a roofing permit application date on or after 3/1/02 OR the roof is original and built in 2004 or later.**
- B. All roof coverings have a Miami-Dade Product Approval listing current at time of installation OR (for the HVHZ only) a roofing permit application after 9/1/1994 and before 3/1/2002 OR the roof is original and built in 1997 or later.**
- C. One or more roof coverings do not meet the requirements of Answer "A" or "B".**
- D. No roof coverings meet the requirements of Answer "A" or "B".**

3. Roof Deck Attachment: What is the weakest form of roof deck attachment?

- A. Plywood/Oriented strand board (OSB) roof sheathing attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by staples or 6d nails spaced at 6" along the edge and 12" in the field OR Batten decking supporting wood shakes or wood shingles OR Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that has an equivalent mean uplift less than that required for Options B or C below.**
- B. Plywood/OSB roof sheathing with a minimum thickness of 7/16"inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 12" inches in the field.-OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent or greater resistance 8d nails spaced a maximum of 12 inches in the field or has a mean uplift resistance of at least 103 psf**
- C. Plywood/OSB roof sheathing with a minimum thickness of 7/16"inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 6" inches in the field. -OR- Dimensional lumber/Tongue & Groove decking with a minimum of 2 nails per board (or 1 nail per board if each board is equal to or less than 6 inches in width). -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent or greater resistance than 8d common nails spaced a maximum of 6 inches in the field or has a mean uplift resistance of at least 182 psf.**
- D. Reinforced Concrete Roof Deck**
- E. Other**
- F. Unknown or unidentified**
- G. No attic access**

Inspector Initials EL Property Address 121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009



24 HOUR TURN-A-ROUND
contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

4. Roof to Wall Attachment:

What is the WEAKEST roof to wall connection? (Do not include attachment of hip/valley jacks within 5 feet of the inside or outside corner of the roof in determination of WEAKEST type)

- A. Toe Nails
B. Clips
C. Single Wraps
D. Double Wraps
E. Structural - Anchor bolts structurally connected / reinforced concrete roof.
F. Other:
G. Unknown or unidentified
H. No attic access

5. Roof Geometry:

What is the roof shape? (Do not consider roofs of porches or carports that are attached only to the fascia or wall of the host structure over unenclosed space in the determination of roof perimeter or roof area for roof geometry classification).

- A. Hip Roof
B. Flat Roof
C. Other Roof

6. Secondary Water Resistance (SWR):

(standard underlayments or hot-mopped felts do not qualify as an SWR)

- A. SWR (also called Sealed Roof Deck) Self-adhering polymer modified-bitumen roofing underlayment applied directly to the sheathing or foam adhesive SWR barrier (not foamed-on insulation) applied as a supplemental means to protect the dwelling from water intrusion in the event of roof covering loss.
B. No SWR
C. Unknown or undetermined

Inspector Initials EL Property Address 121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy. This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

Opening Protection Level Chart 7. Opening Protection: What is the weakest form of wind borne debris protection installed on the structure? First, use the table to determine the weakest form of protection for each category of opening. Second, (a) check one answer below (A, B, C, N, or X) based upon the lowest protection level for ALL Glazed openings and (b) check the protection level for all Non-Glazed openings (.1, .2, or .3) as applicable. Place an "X" in each row to identify all forms of protection in use for each opening type. Check only one answer below (A thru X), based on the weakest form of protection (lowest row) for any of the Glazed openings and indicate the weakest form of protection (lowest row) for Non-Glazed openings.		Glazed Openings				Non-Glazed Openings	
		Windows or Entry Doors	Garage Doors	Skylights	Glass Block	Entry Doors	Garage Doors
N/A	N/A Not Applicable- there are no openings of this type on the structure		X	X	X		X
A	Verified cyclic pressure & large missile (9-lb for windows doors/4.5 lb for skylights)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B	Verified cyclic pressure & large missile (4-8 lb for windows doors/2 lb for skylights)						
C	Verified plywood/OSB meeting Table 1609.1.2 of the FBC 2007						
D	Verified Non-Glazed Entry or Garage doors indicating compliance with ASTM E 330, ANSI/DASMA 108, or PA/TAS 202 for wind pressure resistance.						
N	Opening Protection products that appear to be A or B but are not verified Other protective coverings that cannot be identified as A, B, or C						
X	No Windborne Debris Protection						

- A. Exterior Openings Cyclic Pressure and 9-lb Large Missile (4.5 lb for skylights only)**
All Glazed openings are protected at a minimum, with impact resistant coverings or products listed as wind borne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level A in the table above).
 - Miami-Dade County PA 201, 202, and 203 • For Garage Doors Only: ANSI/DASMA 115 • For Skylights Only: ASTM E 1886 and ASTM E 1996 • Southern Standards Technical Document (SSTD) 12 • Florida Building Code Testing Application Standard (TAS) 201, 202, and 203 • American Society for Testing and Materials (ASTM) E 1886 and ASTM E 1996.
 - A.1 All Non-Glazed openings classified as A in the table above, or no Non-Glazed openings exist
 - A.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level B, C, N, or X in the table above
 - A.3 One or More Non-Glazed Openings is classified as Level B, C, N, or X in the table above
- B. Exterior Opening Protection- Cyclic Pressure and 4 to 8-lb Large Missile (2-4.5 lb for skylights only)**
All Glazed openings are protected, at a minimum, with impact resistant coverings or products listed as windborne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level B in the table above):
 - ASTM E 1886 and ASTM E 1996 (Large Missile – 4.5 lb. • SSTD 12 (Large Missile – 4 lb. to 8 lb.) • For Skylights Only: ASTM E 1886 & ASTM E 1996 (Large Missile 2 to 4.5 lb.)
- C. Exterior Opening Protection- Wood Structural Panels meeting FBC 2007**
All Glazed openings are covered with plywood/OSB meeting the requirements of Table 1609.1.2 of the FBC 2007 (Level C in the table above).
- N. Exterior Opening Protection (unverified shutter systems with no documentation)**
All Glazed openings are protected with protective coverings not meeting the requirements of Answer "A", "B", or "C" or systems that appear to meet Answer "A" or "B" with no documentation of compliance (Level N in the table above).
- X. None or Some Glazed Openings** One or more Glazed openings classified and Level X in the table above.

Inspector Initials EL Property Address 121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy. This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

MITIGATION INSPECTIONS MUST BE CERTIFIED BY A QUALIFIED INSPECTOR.
 Section 627.711(2), Florida Statutes, provides a listing of individuals who may sign this form.

Qualified Inspector Name: MICHAEL DIGIORGIO	License Type: CGC	License or Certificate #: 033997
Inspection Company: FLEET INSPECTIONS	Phone: (954) 752 9443	

Qualified Inspector – I hold an active license as a _____ : (check one)

Home inspector licensed under Section 468.8314, Florida Statutes who has completed the statutory number of hours of hurricane mitigation training approved by the Construction Industry Licensing Board and completion of a proficiency exam.
 Building code inspector certified under Section 468.607, Florida Statutes.

General, building or residential contractor licensed under Section 489.111, Florida Statutes.

Professional engineer licensed under Section 471.015, Florida Statutes.
 Professional architect licensed under Section 481.213, Florida Statutes.
 Any other individual or entity recognized by the insurer as possessing the necessary qualifications to properly complete a uniform mitigation verification form pursuant to Section 627.711(2), Florida Statutes.

Individuals other than licensed contractors licensed under Section 489.111, Florida Statutes, or professional engineer licensed under Section 471.015, Florida Statutes, must inspect the structures personally and not through employees or other persons. Licensees under s.471.015 or s.489.111 may authorize a direct employee who possesses the requisite skill, knowledge, and experience to conduct a mitigation verification inspection.

I, **MICHAEL DIGIORGIO** (print name) am a qualified inspector and I personally performed the inspection or (licensed(print name)contractors and professional engineers only)

I had my employee (**Eli Levrey**) perform the inspection(print name of inspector)and I agree to be responsible for his/her work.
 (print name of inspector)

Qualified inspector signature: 04/07/2021

An individual or entity who knowingly or through gross negligence provides a false or fraudulent mitigation verification form is subject to investigation by the Florida Division of Insurance Fraud and may be subject to administrative action by the appropriate licensing agency or to criminal prosecution. (Section 627.711(4)-(7), Florida Statutes) The Qualified Inspector who certifies this form shall be directly liable for the misconduct of employees as if the authorized mitigation inspector personally performed the inspection.

Homeowner to complete: I certify that the named Qualified Inspector or his or her employee did perform an inspection of the residence identified on this form and that proof of identification was provided to me or my Authorized Representative.

Signature: Date: 04/07/2021

An individual or entity who knowingly provides or utters a false or fraudulent mitigation verification form with the intent to obtain or receive a discount on an insurance premium to which the individual or entity is not entitled commits a misdemeanor of the first degree. (Section 627.711(7), Florida Statutes)

The definitions on this form are for inspection purposes only and cannot be used to certify any product or construction feature as offering protection from hurricanes.



24 HOUR TURN-A-ROUND



contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

[TO VIEW DEFICIENCY PHOTOS PLEASE GO BACK TO THE PREVIOUS PAGE](#)

121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009

PHOTO PAGES

ELEVATION





24 HOUR TURN-A-ROUND




contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009

UNGLAZED OPENINGS





24 HOUR TURN-A-ROUND



contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009

GLAZED OPENINGS





24 HOUR TURN-A-ROUND



contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155





24 HOUR TURN-A-ROUND




contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

GLAZED OPENINGS II





24 HOUR TURN-A-ROUND

contact us for details



(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.

This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155





24 HOUR TURN-A-ROUND



contact us for details
(954) 752-9443
(888) 505-0828



Uniform Mitigation Verification Inspection Form. Maintain a copy of this form and any documentation provided with the insurance policy.
This verification form is valid for up to five (5) years provided no material changes have been made to the structure. OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

121 GOLDEN ISLES DR, HALLANDALE BEACH FL 33009

ROOF COVERING

